Energy Consumption and Greenhouse Gas Emissions Reporting - for 2017

Confirm consecutive 12-mth period (mth-yr to mth-yr)	Jan/2017 - Dec/2017
Sector	Acute/Chronic Hospital
Agency Sub-sector	Public Hospital
Organization Name	Dryden Regional Health Centre

Operation Name	Operation Type	Address	City	Postal Code	Total Floor Area	Unit	Avg hrs/wk	Electricity Quantity	Electricity Unit	Natural Gas Quantity	Natural Gas Unit	Fuel Oil 1 & 2 Quantity	Fuel Oil 1 & 2 Unit	Fuel Oil 4 & 6 Quantity	Fuel Oil 4 & 6 Unit	Propane Quantity	Propane Unit	Coal Quantity	Coal Unit	Wood Quantity	Wood Unit	District Heating Quantity	District Heating Unit	Renewable?	If Yes, enter Emission Factor	District Cooling Quantity	District Cooling Unit	Renewable?	If Yes, enter Emission Factor	GHG Emissions (Kg)	Energy Intensity (ekWh/sqft)	Building / Operation Identifier	Comments
Stephenson Building	*Administrative offices and related facilities*	*2160 Yonge Street*	*Toronto*	*M7A 2G5*	*135,034.00*	*Square feet*	*70*	*2,181,065.00000*	*kWh*	*125,300.00000*	*Cubic meter*	*110,000.00000*	*Litre*	*23,000.00235*	*Litre*		*Litre*		*Metric Tonne*		*Metric Tonne*	*26.73000*	*Giga Joule*	*No*	*0.00000*	*20.50600*	*KL Chilled Water*	*No*	*0.00000*				*max. 255 characters*
Ambulance Garage	Facilities used for hospital purposes	58 Goodall Street	Dryden	P8N 1V8	3,638.00	Square feet	168	35,518.77960	kWh	6,045.00000	Cubic Meter																			12,043.24406	27.42267		
Dryden Regional Health Centre	Facilities used for hospital purposes	58 Goodall Street	Dryden	P8N 1V8	75,022.60	Square feet	168	4,646,340.00000	kWh	451,065.00000	Cubic Meter																			933,168.05708	125.83086		